



STORMWATER
ENTERPRISE

POLICY STATEMENT

SUBJECT: REQUIREMENTS FOR STORM DRAIN VIDEO INSPECTIONS

DATE: JUNE 6, 2020

OVERVIEW:

Provide an explanation of requirements necessary for storm drain video inspections and submittal

DETAILS:

- Each video shall have an attached report that refers to stationing or feature numbers from the approved plans. The report shall also reference:
 - The subdivision name and filing
 - Date and time of inspection
 - Drainage Basin

- Each feature in a storm line must be identified, including:
 - Pipe size
 - Pipe material
 - Length of pipe
 - Direction of travel (upstream or downstream)
 - Laterals – including sizes
 - Significant bends
 - Transitions
 - Underdrain tie-ins
 - Steps at manholes and
 - Areas where damages have been repaired

- If something was significantly changed in the alignment or location of bends or manholes, the changes must be called out and marked up on the plans. As-built plans must be provided.

- The entire system must be videoed. Laterals may be omitted, but only if there is an unobstructed view from the mainline to the inlet.

- Copies of the Video are to be provided on labeled flash drives.